



Biomass – Hydrogen –CHP –CCS: UNIFHY and BLAZE projects

Prof. Ing. Enrico Bocci

Associate Professor of Thermo-Electrochemical conversion systems

Director of
The Paolo Emilio Laborarory

Member of
CIRPS - Centro di ricerca per lo Sviluppo sostenibile

Università degli Studi Guglielmo Marconi

- Goal: thermal system for continuous hydrogen (purity PEMFC grade) production from solid and liquid biomass
- Way: materials and reactors at a precommercial scale, by-products and effluents, LCA/LCI analysis, Economical assessment of pre-treatment of feedstock (sewage sludge, MO, other wastes)


TARGET

- Efficiency: HV gas/feedstock > 66%, including purification
- Cost: 5 €/kg of H₂, including CAPEX
- Durability: > 10 years (80,000 h) with availability > 95%
- Scalability: to 500 kg/day


PROJECT OVERVIEW




- UNifHY: UNIQUE gasifier for hydrogen production
- Call topic: SP1-JTI-FCH.2011.2.3 BTH - Biomass-to-hydrogen (Thermochemical route)
- Duration: 09-01-2012 / 08-31-2015
- Budget: 3,555,652.00 €, EU contribution: 2,203,599.00 €
- Overall purpose of project: The project aims to develop a biomass steam gasification process coupled to syngas purification to produce pure hydrogen from biomass, increase well-to-tank efficiency and contribute to a sustainable energy portfolio, exploiting results obtained in past R&D EU projects on hot gas catalytic conditioning.
- Stage of implementation: Mid Term review passed satisfactorily, 05-14-2014



The 1000 kWth UNIfHY Integrated Plant



The heating up phase



TIR 01: Temp. at the bottom of the gasifier

TIR 03: Temp. at the top of the gasifier

($\cong$ Top of the ceramic candles)

TIR 09: Temp. inside the bed material

TIR 02: Temp. at the surface of the bed material


($\cong$ Bottom of the ceramic candles)



Operation of the integrated system



Gasification Temperature-week 09-13/11/2015




Operating conditions (11 Nov 2015)

Biomass feeding rate ^{a)} (kg _{dry} /h; kg _{wet} /h)	122; 140
O ₂ (kg/h)	44 - 46
Steam (kg/h)	48 - 50
Equivalence Ratio (ER)	0.25
Steam/Biomass ^{b)} (S/B)	0.4
Feeding rate to PPS (Nm ³ _{dry} /h; @ H ₂ O 35 %w)	25 - 30

^{a)} Moisture content: 12 %-wt; ^{b)} Biomass dry


Product gas composition (12 Nov 2015)




	Average gas composition (%v, dry)						
	CO	CO ₂	CH ₄	CnHm	H ₂	O ₂	N ₂
Average	26.5	34.3	10.0	0.54	28.5	not det.	0.12
St. dev.	1.3	1.5	0.9	0.07	1.8		0.3

H₂ from the PPS

H₂ stream from the PPS (18 nov 2015)



Ora	Sampling time	H ₂ (%v)						
		CO	CO ₂	CH ₄	CnHm	H ₂	O ₂	N ₂
22:59:00	03:39:00	0,93	0,33	0,62	0,00	94,83	1,07	2,22
23:00:30	03:40:30	0,97	0,26	0,64	0,00	98,11	0,00	0,02
23:02:00	03:42:00	0,86	0,28	0,60	0,00	98,24	0,00	0,02
23:03:30	03:43:30	0,78	0,19	0,63	0,00	98,38	0,00	0,02
23:05:00	03:45:00	0,76	0,24	0,60	0,00	98,38	0,00	0,02
23:06:30	03:46:30	0,63	0,18	0,57	0,00	98,61	0,00	0,01
23:08:00	03:48:00	0,61	0,18	0,60	0,00	98,59	0,00	0,02
23:09:30	03:49:30	0,56	0,13	0,54	0,00	98,74	0,00	0,03
23:11:00	03:51:00	0,46	0,00	0,51	0,00	99,01	0,00	0,02
23:12:30	03:52:30	0,46	0,06	0,52	0,00	98,93	0,00	0,03
23:14:00	03:54:00	0,38	0,00	0,51	0,00	99,10	0,00	0,01
23:15:30	03:55:30	0,35	0,10	0,49	0,00	99,04	0,00	0,02
23:17:00	03:57:00	0,34	0,00	0,50	0,00	99,14	0,00	0,02
23:18:30	03:58:30	0,29	0,10	0,47	0,00	99,20	0,00	-0,06
0:44:00	05:24:00	0,07	0,00	0,45	0,00	99,46	0,00	0,02




BLAZE

Biomass Low cost Advanced Zero Emission small-to-medium scale integrated gasifier - fuel cell CHP plant



Flexible electricity supply and heat integration with agro, industrial or buildings



CHP IN EU-28 (Eurostat)

- 120 GWe (ST 50%, CC 25%, ICE 13%, GT 10%): 362 TWh -> ≈3000 AEh (≈ 11% of electricity demand).
- 300 GW_{th}: 775 TWh -> ≈ 2500 AEh
- space heating ≈ 50% process heating (Germany, Italy, Poland and the Netherlands largest capacity)
- Natural gas ≈ 50%, solid fossil fuels and peat ≈ 20% , oil and oil products 5%, biomass (timber by-products, black liquor, wood, straw, animal waste, OFMSW) attained 20% but there is difficulty in converting different biomass feedstocks in a Reliable and Economic (Efficient and Clean) way
- Zero Energy Buildings (ZEB&ZED) from 31st December 2020 (public buildings from 31st December 2018)

BLAZE OBJECTIVES

- overall 90% (versus 65%, target SET-PLAN 75%)
- electrical 50% (versus 25%, target SET-PLAN >30%)
- near-zero gaseous and PM emissions
- CAPEX below 4,000 €/kWe (actual 10,000 €/kWe)
- OPEX of ≈ 0.05 €/kWhe (actual 0.10 €/kWhe)
- electricity production cost 0.10 €/kWh (actual 0.22 €/kWh, SET-PLAN target of 20% cost reduction by 2020, and 50% by 2030).

BLAZE ACTIVITIES




Fig. 2. UNITE gasification and UNIVAQ catalyst and sorbent test rig






Fig. 3. ENEA gasification and EPFL/SP stack SOFC test rig



100 kWth Gasifier



Togheter with **WT** and **USGM**, **UNIVAQ** developed the 100 kWth dual fluidized bed gasifier used in **BLAZE**



SOFC system



Large Stack Module (LSM)

- Power output 25 kWe,
integrating 4 stacks of 6.5 kWe
- Fuel: H₂, SMR (preliminary)
 - Max convertible flow H₂:
280NL/min
 - Max convertible flow CH₄:
70NL/min
- Oxidant: Air
 - Maximum tolerated flow 5600 NL/min
- 1699 x 792 x 1385 mm
- 1505 kg



BIOMASS CHP COST PER ELECTRIC KWh



	BLAZE		ICE		ORC	
Equivalent annual hours	3000	2500	3000	2500	3000	2500
OPEX €/kWh	0.06	0.03	0.16	0.04	0.20	0.04
CAPEX €/kWh	0.08	0.03	0.11	0.02	0.13	0.02
Tot CAPEX+OPEX €/kWh	0.14	0.06	0.27	0.06	0.33	0.06
Equivalent annual hours	7500	7500	7500	7500	7500	7500
OPEX €/kWh	0.04	0.02	0.12	0.03	0.14	0.03
CAPEX €/kWh	0.06	0.02	0.07	0.01	0.06	0.01
Tot CAPEX+OPEX €/kWh	0.10	0.04	0.19	0.04	0.20	0.04

The table shows that BLAZE is the only system that, in case of lower annual equivalent hours, has a competitive electricity generation cost, and that BLAZE, in case of high annual equivalent hours, can reach electricity generation cost below 0.10 €/kWh.

tar and contaminants

- literature overview (www.blazeproject.eu/resources) analyzing 83 papers (mostly experimental).
- representative syngas composition: 45% H₂, 24% CO, 11% CO₂, 2% CH₄, 18% H₂O
- 2 organic (toluene and naphthalene to represent so-called slow and fast tars)
- 3 inorganic (H₂S, KCl; HCl) representative contaminants
- 25 mg/Nm³ (5 ppm) and 75 mg/Nm³ (15 ppm) naphthalene
- 250 mg/Nm³ (to be expected from clean biomass such as almond shells) and 750 mg/Nm³ (feedstock emitting high toluene concentrations)
- H₂S (sulfur compounds) have to be reduced to 1-3 ppm
- KCl represent both halogens and alkalis: 50-200 ppm KCl



THANKS FOR THE ATTENTION

ENRICO BOCCI

e.bocci@unimarconi.it 00393288719698

www.blazeproject.eu

info@blazeproject.eu